



NEMO|etc.

Certificate of Authorization #32455
353 Christian Street, Unit #13
Oxford, CT 06478
(203) 262-9245

ENGINEER

TEST

CONSULT

P.E. EVALUATION REPORT (PEER)

Polyglass USA, Inc.

1111 West Newport Center Drive
Deerfield Beach, FL 33442
(866) 794-9659

PEER-PLYG-005.C.R2

FL47068-R2 (NON-HVHZ)

Date of Issuance: 12/20/2024

Revision 2: 08/12/2025

SCOPE:

This P.E. Evaluation Report (henceforth 'PEER') is issued under **F.A.C. Rule 61G20-3** and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for compliance with the **8th Edition (2023) Florida Building Code** [sections noted herein](#).

DESCRIPTION: Polyglass Polyurea / Polyurethane Waterproofing Systems (NON-HVHZ)

LABELING: Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein.


CONTINUED COMPLIANCE: This PEER is valid until such time as the named product(s) changes, the referenced Quality Assurance or production facility location(s) changes, or Code provisions that relate to the product(s) change. Acceptance of our PEERs by the named client constitutes agreement to notify NEMO ETC, LLC of any changes to the product(s), the Quality Assurance or the production facility location(s). NEMO ETC, LLC requires a complete review of its PEER relative to updated Code requirements with each Code Cycle.

ADVERTISEMENT: "NEMO P.E. Evaluated" may be displayed in advertising literature. If any portion of the PEER is displayed, then it shall be in its entirety.

INSPECTION: Upon request, a copy of this entire PEER shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This PEER consists of pages 1 through 4, plus 2-pages of Appendix.

Prepared by:



CERTIFICATION OF INDEPENDENCE:

1. NEMO ETC, LLC does not have, nor does it intend to acquire, or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the PEERs are being issued.
4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
5. This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

ROOFING SYSTEMS EVALUATION:

1. SCOPE:

Product Category: Roofing
Sub-Category: Waterproofing
Product Approval Method: Method 1, Option D – Codified Material, Evaluation by Engineer
Compliance Statement: Polyglass Polyurea / Polyurethane Systems, as produced by Polyglass USA, Inc., have demonstrated compliance with the following sections of the **8th Edition (2023) Florida Building Code** through testing in accordance with the following Standards. Compliance is subject to the [Installation Requirements](#) and [Limitations of Use](#) set forth herein.

2. STANDARDS:

| SECTION | PROPERTY | STANDARD |
|-----------|-------------------|-----------------|
| 1504.3.1 | Wind resistance | FM 4474 |
| 1507.15.2 | Material standard | ASTM C836, C957 |

3. REFERENCES:

| ENTITY | EXAMINATION | REFERENCE | DATE |
|------------------|--------------------|--------------------|------------|
| PRI (TST5878) | ASTM C957 | 708T0266 | 12/07/2024 |
| PRI (TST5878) | ASTM C957 | 708T0267 | 12/07/2024 |
| PRI (TST5878) | ASTM C836 | 708T0270.1 | 12/18/2024 |
| PRI (TST5878) | ASTM C836 | 708T0271.1 | 12/18/2024 |
| PRI (TST5878) | ASTM C836 | 708T0279.1.1 | 12/18/2024 |
| PRI (TST5878) | ASTM C836 | 708T0279.2.1 | 12/18/2024 |
| PRI (TST5878) | FM 4474/TAS 114(D) | 708T0269 | 09/18/2024 |
| UL LLC (QUA9625) | Quality Control | Order Confirmation | 12/03/2024 |

4. PRODUCT DESCRIPTION:

4.1 This PEER covers Polyglass Polyurea / Polyurethane Systems applied to Approved substrates as outlined in the [Limitations of Use](#) herein. The following products make up the subject systems.

| TYPE | PRODUCT | USE | MATERIAL STANDARD | PLANT(S) |
|---|-------------------------------|---|---|------------------|
| Two-part, hot spray polyurea | Tecnocoat H-2049 | Waterproofing in split-slab construction | ASTM C836 | Barcelona, Spain |
| | Tecnocoat P-2049 | | | |
| Two-part, cold-applied polyurea | Tecnocoat CP-2049 | Base Coat in multi-coat systems or Waterproofing in split-slab construction | | |
| | Tecnocoat CP-2049 Brush Grade | | | |
| Two-part, aromatic and fluid polyurethane | TecnoFloor PU-3060 | Intermediate Coat in multi-coat systems | ASTM C957 (with Tecnocoat CP 2049 base coat) | |
| Two-part, aliphatic, polyurethane | TecnoTop 2C | Intermediate or Top Coat in multi-coat systems | | |

5. LIMITATIONS:

- 5.1 This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance. PEERs are not to be construed as representing any attributes not specifically listed, nor are PEERs to be construed as an endorsement of the subject, or a recommendation for its use. There is no warranty by NEMO ETC, LLC or Robert Nieminen, P.E., express or implied, as to any finding or other matter in this PEER, or as to any product covered by the PEER.
- 5.2 This PEER is not for use in FBC High Velocity Hurricane Zone jurisdictions, as defined in FBC Chapter 2 (Broward and Miami-Dade Counties).
- 5.3 This PEER pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
- 5.4 This PEER does not include evaluation of fire classification. Refer to **FBC 1505** for requirements and limitations regarding roof assembly fire classification. Refer to **FBC 2603** for requirements and limitations concerning the use of foam plastic insulation.
- 5.5 This PEER does not include evaluation of roof edge termination. Refer to **FBC 1504.5** for requirements and limitations regarding edge securement for low-slope roofs.
- 5.6 Refer to **FBC 1511** for requirements and limitations regarding recover installations.
- 5.6.1 RESERVED
- 5.6.2 For bonded insulation or membrane over existing substrates in a re-roof (tear off) or recover installation, the existing deck or existing roof surface shall be examined for compatibility with the adhesive to be installed. If any surface conditions exist that bring system performance into question, field uplift testing in accordance with [ANSI/SPRI IA-1](#), [ASTM E907](#), [FM Loss Prevention Data Sheet 1-52](#) or [Testing Application Standard TAS 124](#) shall be conducted on mock-ups of the proposed new roof assembly.
- 5.6.3 RESERVED
- 5.7 Refer to Appendix 1 for system attachment requirements for wind load resistance.
- 5.7.1 “MDP” = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads, and reflects the ultimate passing pressure divided by 2 (the 2 to 1 margin of safety per **FBC 1504.9** has already been applied). Refer to **FBC 1609** for determination of design wind loads.
- 5.7.2 RESERVED
- 5.7.3 For assemblies with all components fully bonded in place, the maximum design pressure for the selected assembly shall meet or exceed critical design pressure determined in accordance with **FBC Chapter 16**. No rational analysis is permitted for these systems.

- 5.8 All components in the roof assembly shall have quality assurance audit in accordance with **F.A.C. Rule 61G20-3**. Refer to the Product Approval of the component manufacturer for components listed in Appendix 1 that are produced by a Product Manufacturer other than the report holder on [Page 1](#) of this PEER.
- 5.8.1 For proprietary overburden products listed in Appendix 1, which are produced by a Product Manufacturer other than the report holder on Page 1 of this PEER:
- Neither NEMO ETC, LLC nor Robert Nieminen, P.E. purport to have evaluated said overburden components for Code compliance. The scope of evaluation in Appendix 1 is limited to the as-tested interface between said overburden components and the waterproofing systems referenced therein.
 - Refer to the [Product Approval](#) or [Miami-Dade NOA](#) of the component manufacturer to confirm Quality Assurance in accordance with **F.A.C. Rule 61G20-3**.
 - Proprietary exterior elevated flooring systems shall demonstrate compliance with **FBC 3115** to the satisfaction of the Authority Having Jurisdiction.
- 5.8.2 For proprietary Independent Elevated Flooring Systems (e.g., FBC FPA FL27442 or FL46557), as defined in **FBC 3115.1.2**:
- The Independent Elevated Flooring Systems shall hold current Florida Product Approval, documenting compliance with **FBC 3115** to the satisfaction of the Authority Having Jurisdiction.
 - The design pressure limitation for the selected waterproofing system herein is unrelated to any such limitation of the Independent Elevated Flooring System, and shall be viewed independently thereof.

6. INSTALLATION:

Polyglass Polyurea / Polyurethane Waterproofing Systems shall be installed in accordance with **Polyglass USA, Inc.** current, published installation instructions, subject to the [Limitations of Use](#) noted herein. Flashing and detailing shall be in accordance with Polyglass published installation instructions using Polyglass specified materials to establish a watertight condition.

7. BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or Authority Having Jurisdiction to properly evaluate the installation of this product.

8. MANUFACTURING PLANTS:

Contact the named QA entity for manufacturing facilities covered by **F.A.C. Rule 61G20-3** QA requirements. Refer to [Section 4](#) herein for products and production locations having met codified material standards.

9. QUALITY ASSURANCE ENTITY:

[UL, LLC. – QUA9625](#); (847) 664-1668; bsai.inspections@ul.com

- THE 2-PAGES THAT FOLLOW FORM PART OF THIS PEER -

APPENDIX 1: ATTACHMENT REQUIREMENTS FOR WIND UPLIFT RESISTANCE
The following notes apply to the systems outlined herein:

1. The roof system evaluation herein pertains to above-deck waterproofing components. Decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.
2. For assemblies with all components fully bonded, the maximum design pressure for the selected assembly shall meet or exceed critical design pressure determined in accordance with FBC Chapter 16. No rational analysis is permitted for these systems.
3. For re-roof (tear off) installation, the existing deck shall be examined for compatibility with the adhesive to be installed. If any surface conditions exist that bring system performance into question, field uplift testing in accordance shall be conducted on mock-ups of the proposed new roof assembly. Field uplift testing shall be in accordance with [ASTM E907](#), [FM Loss Prevention Data Sheet 1-52](#) or [Testing Application Standard TAS 124](#).
4. For bonded membrane applications, unless otherwise noted, refer to the following for system components and application rates.

| APPLICATION RATES | | |
|--------------------------|--------------------|---|
| PRODUCT USE | PRODUCT NAME | RATE |
| Primer | Primer EP-1010 | Short nap roller or notched trowel to min. 10 wet-mils |
| Base Coat | Tecnocoat CP-2049 | Short nap roller or notched trowel to min. 80 wet-mils |
| Intermediate Coat | TecnoFloor PU-3060 | Short nap roller, notched trowel or squeegee to 20-30 wet-mils. |
| Intermediate or Top Coat | TecnoTop 2C | Short nap roller, or airless spray to min. 7 wet-mils |
| Waterproofing | Tecnocoat CP-2049 | Short nap roller or notched trowel to min. 80 wet-mils |
| | Tecnocoat P-2049 | High pressure spray to min 80 wet-mils |
| | Tecnocoat H-2049 | High pressure spray to min 80 wet-mils |

- 4.1 The seeding and back-rolling of aggregate shall be in accordance with Polyglass published requirements, with an even broadcast to refusal. Any loose aggregate should be removed prior to recoating.
5. “MDP” = Maximum Design Pressure is the result of testing for wind load resistance based on allowable wind loads. Refer to FBC 1609 for determination of design wind loads for determination of design wind loads. [\(Note 2\)](#)
6. Overburden of soil and plantings (for ‘garden roofs’; root barriers, filter fabric, drainage components, EPS / XPS insulation, etc.), concrete topping slabs or Independent Elevated Flooring Systems, that are specified by the Designer of Record, acceptable to the Authority Having Jurisdiction and do not form part of the load path to the waterproofing system, are permissible over the assemblies noted herein with no adverse effect on the wind uplift performance of the system. The Authority Having Jurisdiction may require integrity flood testing (ASTM D5957) or Electric Field Vector Mapping tests of all waterproofing systems prior to placement of overburden materials. Testing, if required by the Authority Having Jurisdiction, should be conducted by a qualified testing agency or professional.
- 6.1 For proprietary overburden components referenced herein, produced by a Product Manufacturer other than the report holder on Page 1 of this PEER:
 - Neither NEMO ETC, LLC nor Robert Nieminen, P.E. purport to have evaluated said overburden components for Code compliance. The scope of evaluation is limited to the as-tested interface between said overburden components and the waterproofing systems.
 - Refer to the [Product Approval](#) or [Miami-Dade NOA](#) of the component manufacturer to confirm Quality Assurance in accordance with F.A.C. [Rule 61G20-3](#).
 - Proprietary exterior elevated flooring systems shall demonstrate compliance with [FBC 3115](#) to the satisfaction of the Authority Having Jurisdiction.

6.2 For proprietary Independent Elevated Flooring Systems (e.g., FBC FPA FL27442 or FL46557), as defined in [FBC 3115.1.2](#):

- The Independent Elevated Flooring Systems shall hold current Florida Product Approval, documenting compliance with [FBC 3115](#) to the satisfaction of the Authority Having Jurisdiction.
- The design pressure limitation for the selected waterproofing system herein is unrelated to any such limitation of the Independent Elevated Flooring System, and shall be viewed independently thereof.

**TABLE 1: CONCRETE DECKS – NEW CONSTRUCTION OR REROOF (TEAR-OFF)
SYSTEM TYPE F: BONDED WATERPROOFING**

| System No. | Deck (Note 1) | Waterproofing (Note 4) | | | | | Overburden (Note 6) | MDP (psf) |
|------------|-------------------------------|--|------------------------------------|--------------------|--------------------------------------|-------------|---|---------------------------|
| | | Primer | Base Coat / Waterproofing | Intermediate Coat | Aggregate (Note 4.1) | Top Coat | | |
| C-1. | Structural Concrete | Primer EP-1010 | Tecnocoat CP-2049 | N/A | N/A | N/A | Optional FBC Approved extruded polystyrene and/or drainage course, followed by structural concrete topping slab | N/A |
| C-2. | Structural Concrete | Primer EP-1010 | Tecnocoat P-2049 | N/A | N/A | N/A | Optional FBC Approved extruded polystyrene and/or drainage course, followed by structural concrete topping slab | N/A |
| C-3. | Structural Concrete | Primer EP-1010 | Tecnocoat H-2049 | N/A | N/A | N/A | Optional FBC Approved extruded polystyrene and/or drainage course, followed by structural concrete topping slab | N/A |
| C-4. | Structural Concrete | Primer EP-1010 | Tecnocoat CP-2049 | Primer EP-1010 | kiln dried 20/40 mesh silica sand | N/A | Exterior grade ceramic plaza deck tiles (min. 12 x 12 x ½-inch) fully embedded into ANSI A118.1 Portland cement thinset mortar, using a ¼-inch notched trowel per ANSI A108.5 | -502.5 |
| C-5. | Structural Concrete | Primer EP-1010 | Tecnocoat CP-2049 | Primer EP-1010 | kiln dried 20/40 mesh silica sand | N/A | As specified by the Designer of Record and acceptable to the Authority Having Jurisdiction. | -502.5 |
| C-6. | Structural Concrete | Primer EP-1010 | Min. 60 wet-mils Tecnocoat CP-2049 | TecnoFloor PU-3060 | kiln dried 20/40 mesh silica sand | TecnoTop 2C | N/A | -502.5 |
| C-7. | Structural Concrete | Primer EP-1010 | Min. 60 wet-mils Tecnocoat CP-2049 | TecnoTop 2C | kiln dried 20/40 mesh silica sand | TecnoTop 2C | N/A | -502.5 |